

Radon Mitigation Quality Assurance Test

Building Information	2636	District	ASD-W		
Building Name:	Nashwaaksis Middle School				
Year constructed	1976	Phase	6		
Street Address:	324 Fulton Avenue				
City:	Fredericton				
Ventilation System	Y \ N	Mitigation System	Y \ N		
				Telephon Number	
Facilities Manager:					
Name of Person Placing Detectors:					
Instructions:					
Installation					
1) Choose two rooms below, if "R" is indicated in front of the room number, this room must be tested. 2) Write the detector number on the corresponding room number line 3) Write the installation date on the corresponding room number line. 4) Write the installation date on the detector (Start Date). 5) Fax a copy of this sheet after the installation has been complete to (506) 444-5529 or email to pascal.landry@gnb.ca. 6) Keep this page for the duration of the test and return with detectors.					
Collection		<u>The duration of the test will be 90 days.</u>			
1) Collect the two detectors after 90 days 2) Write the collection date on the detector. 3) Write the collection date on the corresponding line below. 4) Return the two detectors and this form to:		Att: Pascal Landry Educational Facilities 250 King Street, Place 2000 Fredericton, NB E3B 9M9			
Nashwaaksis Middle School					
Room No.	Serial Number	Installation Date day/month/year	Collection Date day/month/year	Result Bq/m ³	Uncertainty
R 111	323421	01/02/2016	13/05/2016	63 ± 6%	
R 113	323422	01/02/2016	13/05/2016	48 ± 7%	
R 116	323423	01/02/2016	13/05/2016	37 ± 7%	