

PO Box 826, 9208 Main Street, Florenceville-Bristol, NB E7L 2A9 Phone: (506) 392-5124 Fax: (506) 392-5128

Grades: K-5 **Built:** 1966

Functional Capacity Data	Student Enrollment	Number of Classrooms	Classrooms In Use	School Capacity	Capacity Rating
based on 24 students per class	86	8	7	192	44.8%

# School Enrollment Trends 2001 to Present 160 140 148 150 140 120 100 80 60 40 200 2001 2002 2003 2004 2005 2006 2007 2008 2009 2010 2011 2012 2013 2014 2015 2016 2017 2018

### **Physical Description:**

- Built in 1966.
- Electrical entrance is 400 amps, 230 volt and in good condition. There is capacity available for more circuits.
- Exterior lighting is quartz.
- Interior lighting is fluorescent in good condition; lenses are in poor condition.
- Hot water heating system-- Weil-McLain boiler in good condition.
- There are no ventilation units.
- Heating is controlled by thermostats in the school.
- · Air quality is good.
- Washrooms are fair. Mostly old fixtures with some new flushes.
- Windows are in good condition.
- Exterior doors are in good condition.
- There is no cafeteria.
- Floors are tile and in good condition.
- Ceilings in the hallways are sheetrock. Classrooms have cedar wood ceilings
- Painting is done according to a summer schedule.
- Interior doors are wood: some are fire rated.
- Stairways are enclosed to meet fire separation requirements complete with fire rated doors, frames.
- Gymnasium floor is made of tile in good condition. Square footage is 2387 square feet.
- There is no wheel chair access. There is no lift or elevator.
- There is proper access to the roof.
- · Corridor walls are sheetrock.
- Parking is adequate that is paved and in fair condition. Some potholes.
- Water supply is a well with an ultra-violet system and backflow prevention.
- Roof does not leak.
- Land ownership around the school is residential.
- There is room to expand and the neighborhood is appropriate to maintain a school facility for years to come.
- The school is 1427 square meters.
- There are no known environmental concerns.



PO Box 826, 9208 Main Street, Florenceville-Bristol, NB E7L 2A9 Phone: (506) 392-5124 Fax: (506) 392-5128

Grades: K-5 **Built:** 1966

# **Operational Costs**

Electricity		\$	•	7,237.43
Water/Sewage		\$	;	3,861.36
Garbage Remov	/al	\$	:	2,460.96
Snow Plowing		\$		4,000.02
Heating Fuel		\$	1;	3,409.01
Natural Gas		\$		-
Cleaning Suppli	es/Services	\$	;	3,792.44
Minor Repairs/R		\$	1.	1,313.99
Total		\$	40	6,075.21
Operational Cos	sts Per Square Meter		\$	32.29
Based on:	1427 Sq Meters			
Operational Cos	\$	404.17		
Based on:	86 Enrollment		•	



PO Box 826, 9208 Main Street, Florenceville-Bristol, NB E7L 2A9 Phone: (506) 392-5124 Fax: (506) 392-5128

Grades: K-5 **Built:** 1966

### **Feeder Schools**

Students enrolled in the English Prime program at Bristol Elementary School move to Florenceville Middle School for grades 6-8. Students enrolled in French Immersion for grade 3 move to Florenceville Elementary School.

### **Catchment Area Boundaries**

North to #9450 Route 105; West to the Saint John river; East to #290 Lockard Mill Road and #7800 Route 107; South to #9280 Route 105, #1360 Route 570, #770 East Coldstream Road, #746 Route 580 and #860 Knowlesville Road.




PO Box 826, 9208 Main Street, Florenceville-Bristol, NB E7L 2A9 Phone: (506) 392-5124 Fax: (506) 392-5128

Grades: K-5 **Built:** 1966

# **Enrollment 2013-2018**

	2013	2014	2015	2016	2017	2018
K	16	19	11	20	12	14
1	24	15	19	17	15	13
2	28	28	12	22	14	16
3	15	18	25	10	18	13
4	26	16	18	27	10	18
5	20	26	19	18	28	12
Total	129	122	104	114	97	86





PO Box 826, 9208 Main Street, Florenceville-Bristol, NB E7L 2A9 Phone: (506) 392-5124 Fax: (506) 392-5128

Grades: K-5 **Built:** 1966

# **Major Capital and Capital Improvements Projects 2010-2019**

School Year	Project	Capital	Improvements	Major Capital
2010-2011	Masonry - Brick Repointing	\$	4,300	
2011-2012	Radon	\$	30,649	
2018-2019	Roof Replacement	\$	70,000	
Totals		\$	104,949	\$ -